

## Water Quality Sampling Results

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
1040	NITRATE	08-07-2023	0.76		0.4		10	.4	MG/L
1041	NITRITE	08-07-2023		<	0.4		1	.4	MG/L
2414	1,2,3-TRICHLOROPROPANE	08-18-2022		<	0.005		0.005		UG/L
1040	NITRATE	08-04-2022		<	0.4		10	.4	MG/L
1041	NITRITE	08-04-2022		<	0.4		1	.4	MG/L
1025	FLUORIDE	08-30-2021	1.6		0.1		2	.1	MG/L
0100	TURBIDITY	08-09-2021	0.29		0.1		5	.1	NTU
1002	ALUMINUM	08-09-2021		<	50		1000	50	UG/L
1005	ARSENIC	08-09-2021		<	2		10	2	UG/L
1010	BARIUM	08-09-2021		<	100		1000	100	UG/L
1015	CADMIUM	08-09-2021		<	1		5	1	UG/L
1017	CHLORIDE	08-09-2021	28		1		500		MG/L
1020	CHROMIUM	08-09-2021		<	10		50	10	UG/L
1021	HYDROXIDE AS CALCIUM CARBONATE	08-09-2021		<	5				MG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
1022	COPPER, FREE	08-09-2021		<	50		1000	50	UG/L
1024	CYANIDE	08-09-2021		<	100		150	100	UG/L
1025	FLUORIDE	08-09-2021	2.3		0.1		2	.1	MG/L
1028	IRON	08-09-2021		<	100		300	100	UG/L
1030	LEAD	08-09-2021		<	5			5	UG/L
1031	MAGNESIUM	08-09-2021	31		1				MG/L
1032	MANGANESE	08-09-2021		<	20		50	20	UG/L
1035	MERCURY	08-09-2021		<	1		2	1	UG/L
1036	NICKEL	08-09-2021		<	10		100	10	UG/L
1038	NITRATE-NITRITE	08-09-2021	0.76		0.4		10	.4	MG/L
1039	PERCHLORATE	08-09-2021		<	2		6	2	UG/L
1040	NITRATE	08-09-2021	0.76		0.4		10	.4	MG/L
1041	NITRITE	08-09-2021		<	0.4		1	.4	MG/L
1042	POTASSIUM	08-09-2021	6.6		1				MG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
1045	SELENIUM	08-09-2021		<	5		50	5	UG/L
1050	SILVER	08-09-2021		<	10		100	10	UG/L
1052	SODIUM	08-09-2021	130		5				MG/L
1055	SULFATE	08-09-2021	430		2		500	.5	MG/L
1064	CONDUCTIVITY @ 25 C UMHOS/CM	08-09-2021	1100		2		1600		UMHOS/CM
1074	ANTIMONY, TOTAL	08-09-2021		<	6		6	6	UG/L
1075	BERYLLIUM, TOTAL	08-09-2021		<	1		4	1	UG/L
1079	BORON, TOTAL	08-09-2021	1700		100			100	UG/L
1085	THALLIUM, TOTAL	08-09-2021		<	1		2	1	UG/L
1088	VANADIUM, TOTAL	08-09-2021	9.3		3				UG/L
1095	ZINC	08-09-2021		<	50		5000	50	UG/L
1905	COLOR	08-09-2021		<	3		15		UNITS
1915	HARDNESS, TOTAL (AS CaCO3)	08-09-2021	280		6.6				MG/L
1919	CALCIUM	08-09-2021	60		1				MG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
1920	ODOR	08-09-2021	1		1		3	1	TON
1925	PH	08-09-2021	7.8						pH
1927	ALKALINITY, TOTAL	08-09-2021	63		5				MG/L
1928	ALKALINITY, BICARBONATE	08-09-2021	77		5				MG/L
1929	ALKALINITY, CARBONATE	08-09-2021		<	5				MG/L
1930	TDS	08-09-2021	720		5		1000		MG/L
1994	AGGRESSIVE INDEX	08-09-2021	11.76						AGGR
1997	LANGELIER INDEX (PH(S))	08-09-2021	0.51						LANG
2218	TRICHLOROFUOROMETHANE	08-09-2021		<	5		150	5	UG/L
2224	TRANS-1,3-DICHLOROPROPENE	08-09-2021		<	0.5		.5	.5	UG/L
2228	CIS-1,3-DICHLOROPROPENE	08-09-2021		<	0.5		.5	.5	UG/L
2251	METHYL TERT-BUTYL ETHER	08-09-2021		<	3		13	3	UG/L
2378	1,2,4-TRICHLOROBENZENE	08-09-2021		<	0.5		5	.5	UG/L
2380	CIS-1,2-DICHLOROETHYLENE	08-09-2021		<	0.5		6	.5	UG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
2413	1,3-DICHLOROPROPENE	08-09-2021		<	0.5		.5	.5	UG/L
2904	TRICHLOROTRIFLUOROETHANE	08-09-2021		<	10		1200	10	UG/L
2905	FOAMING AGENTS (SURFACTANTS)	08-09-2021		<	0.1		.5		MG/L
2931	1,2-DIBROMO-3-CHLOROPROPANE	08-09-2021		<	0.01		.2	.01	UG/L
2941	CHLOROFORM	08-09-2021		<	1			1	UG/L
2942	BROMOFORM	08-09-2021		<	1			1	UG/L
2943	BROMODICHLOROMETHANE	08-09-2021		<	1			1	UG/L
2944	DIBROMOCHLOROMETHANE	08-09-2021		<	1			1	UG/L
2946	ETHYLENE DIBROMIDE	08-09-2021		<	0.02		.05	.02	UG/L
2950	TTHM	08-09-2021		<	1		80		UG/L
2955	XYLENES, TOTAL	08-09-2021		<	0.5		1750	0.5	UG/L
2963	XYLENE, META AND PARA	08-09-2021		<	1			.5	UG/L
2964	DICHLOROMETHANE	08-09-2021		<	0.5		5	.5	UG/L
2968	O-DICHLOROBENZENE	08-09-2021		<	0.5		600	.5	UG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
2969	P-DICHLOROBENZENE	08-09-2021		<	0.5		5	.5	UG/L
2976	VINYL CHLORIDE	08-09-2021		<	0.5		.5	.5	UG/L
2977	1,1-DICHLOROETHYLENE	08-09-2021		<	0.5		6	.5	UG/L
2978	1,1-DICHLOROETHANE	08-09-2021		<	0.5		5	.5	UG/L
2979	TRANS-1,2-DICHLOROETHYLENE	08-09-2021		<	0.5		10	.5	UG/L
2980	1,2-DICHLOROETHANE	08-09-2021		<	0.5		.5	.5	UG/L
2981	1,1,1-TRICHLOROETHANE	08-09-2021		<	0.5		200	.5	UG/L
2982	CARBON TETRACHLORIDE	08-09-2021		<	0.5		.5	.5	UG/L
2983	1,2-DICHLOROPROPANE	08-09-2021		<	0.5		5	.5	UG/L
2984	TRICHLOROETHYLENE	08-09-2021		<	0.5		5	.5	UG/L
2985	1,1,2-TRICHLOROETHANE	08-09-2021		<	0.5		5	.5	UG/L
2987	TETRACHLOROETHYLENE	08-09-2021		<	0.5		5	.5	UG/L
2988	1,1,2,2-TETRACHLOROETHANE	08-09-2021		<	0.5		1	.5	UG/L
2989	CHLOROBENZENE	08-09-2021		<	0.5		70	.5	UG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
2990	BENZENE	08-09-2021		<	0.5		1	.5	UG/L
2991	TOLUENE	08-09-2021		<	0.5		150	.5	UG/L
2992	ETHYLBENZENE	08-09-2021		<	0.5		300	.5	UG/L
2996	STYRENE	08-09-2021		<	0.5		100	.5	UG/L
2997	O-XYLENE	08-09-2021		<	0.5			.5	UG/L
4109	GROSS ALPHA PARTICLE ACTIVITY	08-09-2021		<	3	0.570	15	3	PCI/L
C164	LANGELIER INDEX AT SOURCE TEMP.	08-09-2021	-0.10						LANG
1040	NITRATE	06-15-2021	0.7400000		0.4		10	.4	MG/L
4030	RADIUM-228	08-19-2020	1.25		0.23	0.260		1	PCI/L
1040	NITRATE	07-07-2020		<	0.4		10	.4	MG/L
2005	ENDRIN	05-11-2020		<	0.1		2	.1	UG/L
2010	BHC-GAMMA	05-11-2020		<	0.2		.2	.2	UG/L
2015	METHOXYCHLOR	05-11-2020		<	10		30	10	UG/L
2020	TOXAPHENE	05-11-2020		<	1		3	1	UG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
2031	DALAPON	05-11-2020		<	10		200	10	UG/L
2032	DIQUAT	05-11-2020		<	4		20	4	UG/L
2033	ENDOTHALL	05-11-2020		<	45		100	45	UG/L
2034	GLYPHOSATE	05-11-2020		<	25		700	25	UG/L
2035	DI(2-ETHYLHEXYL) ADIPATE	05-11-2020		<	5		400	5	UG/L
2036	OXAMYL	05-11-2020		<	20		50	20	UG/L
2037	SIMAZINE	05-11-2020		<	1		4	1	UG/L
2039	DI(2-ETHYLHEXYL) PHTHALATE	05-11-2020		<	3		4	3	UG/L
2040	PICLORAM	05-11-2020		<	1		500	1	UG/L
2041	DINOSEB	05-11-2020		<	2		7	2	UG/L
2042	HEXACHLOROCYCLOPENTADIENE	05-11-2020		<	1		50	1	UG/L
2046	CARBOFURAN	05-11-2020		<	5		18	5	UG/L
2050	ATRAZINE	05-11-2020		<	0.5		1	.5	UG/L
2051	LASSO	05-11-2020		<	1		2	1	UG/L



Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
2063	2,3,7,8-TCDD	05-11-2020		<	0.005		0.03	0.005	NG/L
2065	HEPTACHLOR	05-11-2020		<			.01	.01	UG/L
2067	HEPTACHLOR EPOXIDE	05-11-2020		<			.01	.01	UG/L
2105	2,4-D	05-11-2020		<	10		70	10	UG/L
2110	2,4,5-TP	05-11-2020		<	1		50	1	UG/L
2274	HEXACHLOROBENZENE	05-11-2020		<	0.5		1	.5	UG/L
2306	BENZO(A)PYRENE	05-11-2020		<	0.1		.2	.1	UG/L
2326	PENTACHLOROPHENOL	05-11-2020		<	0.2		1	.2	UG/L
2383	TOTAL POLYCHLORINATED BIPHENYLS (PCB)	05-11-2020		<	0.5		.5	.5	UG/L
2625	BENTAZON	05-11-2020		<	2		18	2	UG/L
2626	MOLINATE	05-11-2020		<	2		20	2	UG/L
2727	THIOBENCARB (BOLERO)	05-11-2020		<	1		70	1	UG/L
2959	CHLORDANE	05-11-2020		<	0.1		.1	.1	UG/L
4030	RADIUM-228	04-21-2020	1.4200000		0.2	0.220		1	PCI/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
1040	NITRATE	07-16-2019	0.5700000		0.4		10	.4	MG/L
2414	1,2,3-TRICHLOROPROPANE	07-16-2019		<			0.005		UG/L
4030	RADIUM-228	06-24-2019	0.8200000		0.2	0.140		1	PCI/L
2414	1,2,3-TRICHLOROPROPANE	04-17-2019		<			0.005		UG/L
2414	1,2,3-TRICHLOROPROPANE	02-12-2019		<			0.005		UG/L
2414	1,2,3-TRICHLOROPROPANE	12-10-2018		<			0.005		UG/L
0100	TURBIDITY	08-14-2018	0.3000000		0.1		5	.1	NTU
1002	ALUMINUM	08-14-2018		<	50		1000	50	UG/L
1005	ARSENIC	08-14-2018		<	2		10	2	UG/L
1010	BARIUM	08-14-2018		<	100		1000	100	UG/L
1015	CADMIUM	08-14-2018		<	1		5	1	UG/L
1017	CHLORIDE	08-14-2018	26.0000000				500		MG/L
1020	CHROMIUM	08-14-2018		<	10		50	10	UG/L
1021	HYDROXIDE AS CALCIUM CARBONATE	08-14-2018		<					MG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
1022	COPPER, FREE	08-14-2018		<	50		1000	50	UG/L
1024	CYANIDE	08-14-2018		<	100		150	100	UG/L
1025	FLUORIDE	08-14-2018	1.8000000		0.1		2	.1	MG/L
1028	IRON	08-14-2018		<	100		300	100	UG/L
1030	LEAD	08-14-2018		<	5			5	UG/L
1031	MAGNESIUM	08-14-2018	27.0000000						MG/L
1032	MANGANESE	08-14-2018		<	20		50	20	UG/L
1035	MERCURY	08-14-2018		<	1		2	1	UG/L
1036	NICKEL	08-14-2018		<	10		100	10	UG/L
1038	NITRATE-NITRITE	08-14-2018	0.7100000		0.4		10	.4	MG/L
1039	PERCHLORATE	08-14-2018		<	4		6	4	UG/L
1040	NITRATE	08-14-2018	0.7100000		0.4		10	.4	MG/L
1041	NITRITE	08-14-2018		<	0.4		1	.4	MG/L
1042	POTASSIUM	08-14-2018	6.4000000						MG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
1045	SELENIUM	08-14-2018		<	5		50	5	UG/L
1050	SILVER	08-14-2018		<	10		100	10	UG/L
1052	SODIUM	08-14-2018	110.0000000						MG/L
1055	SULFATE	08-14-2018	400.0000000		0.5		500	.5	MG/L
1064	CONDUCTIVITY @ 25 C UMHOS/CM	08-14-2018	1000.0000000				1600		UMHOCM
1074	ANTIMONY, TOTAL	08-14-2018		<	6		6	6	UG/L
1075	BERYLLIUM, TOTAL	08-14-2018		<	1		4	1	UG/L
1079	BORON, TOTAL	08-14-2018	1400.0000000		100			100	UG/L
1080	CHROMIUM, HEX	08-14-2018	1.7000000		1			1	UG/L
1085	THALLIUM, TOTAL	08-14-2018		<	1		2	1	UG/L
1088	VANADIUM, TOTAL	08-14-2018	8.6000000		3				UG/L
1095	ZINC	08-14-2018		<	50		5000	50	UG/L
1905	COLOR	08-14-2018		<			15		UNITS
1915	HARDNESS, TOTAL (AS CaCO3)	08-14-2018	240.0000000						MG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
1919	CALCIUM	08-14-2018	50.0000000						MG/L
1920	ODOR	08-14-2018	1.0000000		1		3	1	TON
1925	PH	08-14-2018	7.9000000						pH
1927	ALKALINITY, TOTAL	08-14-2018	67.0000000						MG/L
1928	ALKALINITY, BICARBONATE	08-14-2018	81.0000000						MG/L
1929	ALKALINITY, CARBONATE	08-14-2018		<					MG/L
1930	TDS	08-14-2018	640.0000000				1000		MG/L
1994	AGGRESSIVE INDEX	08-14-2018	11.7900000						AGGR
1997	LANGELIER INDEX (PH(S))	08-14-2018	0.5500000						LANG
2218	TRICHLOROFUOROMETHANE	08-14-2018		<	5		150	5	UG/L
2224	TRANS-1,3-DICHLOROPROPENE	08-14-2018		<	0.5		.5	.5	UG/L
2228	CIS-1,3-DICHLOROPROPENE	08-14-2018		<	0.5		.5	.5	UG/L
2251	METHYL TERT-BUTYL ETHER	08-14-2018		<	3		13	3	UG/L
2378	1,2,4-TRICHLOROBENZENE	08-14-2018		<	0.5		5	.5	UG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
2380	CIS-1,2-DICHLOROETHYLENE	08-14-2018		<	0.5		6	.5	UG/L
2413	1,3-DICHLOROPROPENE	08-14-2018		<	0.5		.5	.5	UG/L
2414	1,2,3-TRICHLOROPROPANE	08-14-2018		<			0.005		UG/L
2904	TRICHLOROTRIFLUOROETHANE	08-14-2018		<	10		1200	10	UG/L
2905	FOAMING AGENTS (SURFACTANTS)	08-14-2018		<			.5		MG/L
2931	1,2-DIBROMO-3-CHLOROPROPANE	08-14-2018		<			.2	.01	UG/L
2941	CHLOROFORM	08-14-2018		<	1			1	UG/L
2942	BROMOFORM	08-14-2018		<	1			1	UG/L
2943	BROMODICHLOROMETHANE	08-14-2018		<	1			1	UG/L
2944	DIBROMOCHLOROMETHANE	08-14-2018		<	1			1	UG/L
2946	ETHYLENE DIBROMIDE	08-14-2018		<			.05	.02	UG/L
2950	TTHM	08-14-2018	1.2000000				80		UG/L
2955	XYLENES, TOTAL	08-14-2018		<	0.5		1750	0.5	UG/L
2963	XYLENE, META AND PARA	08-14-2018		<	0.5			.5	UG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
2964	DICHLOROMETHANE	08-14-2018		<	0.5		5	.5	UG/L
2968	O-DICHLOROBENZENE	08-14-2018		<	0.5		600	.5	UG/L
2969	P-DICHLOROBENZENE	08-14-2018		<	0.5		5	.5	UG/L
2976	VINYL CHLORIDE	08-14-2018		<	0.5		.5	.5	UG/L
2977	1,1-DICHLOROETHYLENE	08-14-2018		<	0.5		6	.5	UG/L
2978	1,1-DICHLOROETHANE	08-14-2018		<	0.5		5	.5	UG/L
2979	TRANS-1,2-DICHLOROETHYLENE	08-14-2018		<	0.5		10	.5	UG/L
2980	1,2-DICHLOROETHANE	08-14-2018		<	0.5		.5	.5	UG/L
2981	1,1,1-TRICHLOROETHANE	08-14-2018		<	0.5		200	.5	UG/L
2982	CARBON TETRACHLORIDE	08-14-2018		<	0.5		.5	.5	UG/L
2983	1,2-DICHLOROPROPANE	08-14-2018		<	0.5		5	.5	UG/L
2984	TRICHLOROETHYLENE	08-14-2018		<	0.5		5	.5	UG/L
2985	1,1,2-TRICHLOROETHANE	08-14-2018		<	0.5		5	.5	UG/L
2987	TETRACHLOROETHYLENE	08-14-2018		<	0.5		5	.5	UG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
2988	1,1,2,2-TETRACHLOROETHANE	08-14-2018		<	0.5		1	.5	UG/L
2989	CHLOROBENZENE	08-14-2018		<	0.5		70	.5	UG/L
2990	BENZENE	08-14-2018		<	0.5		1	.5	UG/L
2991	TOLUENE	08-14-2018		<	0.5		150	.5	UG/L
2992	ETHYLBENZENE	08-14-2018		<	0.5		300	.5	UG/L
2996	STYRENE	08-14-2018		<	0.5		100	.5	UG/L
2997	O-XYLENE	08-14-2018		<	0.5			.5	UG/L
4109	GROSS ALPHA PARTICLE ACTIVITY	08-14-2018		<	0.8	0.730	15	3	PCI/L
C164	LANGELIER INDEX AT SOURCE TEMP.	08-14-2018	-0.0600000						LANG
1055	SULFATE	12-07-2017	380.0000000		0.5		500	.5	MG/L
1055	SULFATE	09-18-2017	380.0000000		0.5		500	.5	MG/L
1055	SULFATE	06-04-2017	380.0000000		0.5		500	.5	MG/L
1040	NITRATE	05-10-2017	0.4500000		0.4		10	.4	MG/L
1055	SULFATE	03-06-2017	460.0000000		0.5		500	.5	MG/L



Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
1055	SULFATE	12-05-2016	490.0000000		0.5		500	.5	MG/L
1055	SULFATE	09-29-2016	440.0000000		0.5		500	.5	MG/L
1055	SULFATE	06-01-2016	420.0000000		0.5		500	.5	MG/L
1040	NITRATE	05-02-2016	0.5200000		0.4		10	.4	MG/L
1041	NITRITE	05-02-2016		<	0.4		1	.4	MG/L
2414	1,2,3-TRICHLOROPROPANE	05-02-2016		<				0.005	UG/L
1055	SULFATE	03-10-2016	500.0000000		0.5		500	.5	MG/L
1055	SULFATE	12-01-2015	460.0000000		0.5		500	.5	MG/L
1055	SULFATE	06-12-2015	450.0000000		0.5		500	.5	MG/L
1028	IRON	05-22-2015		<	100		300	100	UG/L
0100	TURBIDITY	05-04-2015	1.6000000		0.1		5	.1	NTU
1002	ALUMINUM	05-04-2015	55.0000000		50		1000	50	UG/L
1005	ARSENIC	05-04-2015		<	2		10	2	UG/L
1010	BARIUM	05-04-2015		<	100		1000	100	UG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
1015	CADMIUM	05-04-2015		<	1		5	1	UG/L
1017	CHLORIDE	05-04-2015	26.0000000				500		MG/L
1020	CHROMIUM	05-04-2015		<	10		50	10	UG/L
1021	HYDROXIDE AS CALCIUM CARBONATE	05-04-2015		<					MG/L
1022	COPPER, FREE	05-04-2015		<	50		1000	50	UG/L
1024	CYANIDE	05-04-2015		<	100		150	100	UG/L
1025	FLUORIDE	05-04-2015	1.3000000		0.1		2	.1	MG/L
1028	IRON	05-04-2015	330.0000000		100		300	100	UG/L
1030	LEAD	05-04-2015		<	5			5	UG/L
1031	MAGNESIUM	05-04-2015	39.0000000						MG/L
1032	MANGANESE	05-04-2015		<	20		50	20	UG/L
1035	MERCURY	05-04-2015		<	1		2	1	UG/L
1036	NICKEL	05-04-2015		<	10		100	10	UG/L
1038	NITRATE-NITRITE	05-04-2015	450.0000000		400		10000	400	UG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
1039	PERCHLORATE	05-04-2015		<	4		6	4	UG/L
1041	NITRITE	05-04-2015		<	400		1000	400	UG/L
1042	POTASSIUM	05-04-2015	7.8000000						MG/L
1045	SELENIUM	05-04-2015		<	5		50	5	UG/L
1050	SILVER	05-04-2015		<	10		100	10	UG/L
1052	SODIUM	05-04-2015	120.0000000						MG/L
1055	SULFATE	05-04-2015	490.0000000		0.5		500	.5	MG/L
1064	CONDUCTIVITY @ 25 C UMHOS/CM	05-04-2015	1100.0000000				1600		UMHOS/CM
1074	ANTIMONY, TOTAL	05-04-2015		<	6		6	6	UG/L
1075	BERYLLIUM, TOTAL	05-04-2015		<	1		4	1	UG/L
1079	BORON, TOTAL	05-04-2015	1300.0000000		100			100	UG/L
1085	THALLIUM, TOTAL	05-04-2015		<	1		2	1	UG/L
1088	VANADIUM, TOTAL	05-04-2015	8.8000000		3				UG/L
1095	ZINC	05-04-2015		<	50		5000	50	UG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
1905	COLOR	05-04-2015		<			15		UNITS
1915	HARDNESS, TOTAL (AS CaCO3)	05-04-2015	330.0000000						MG/L
1919	CALCIUM	05-04-2015	69.0000000						MG/L
1920	ODOR	05-04-2015	1.0000000		1		3	1	TON
1925	PH	05-04-2015	7.8000000						pH
1927	ALKALINITY, TOTAL	05-04-2015	55.0000000						MG/L
1928	ALKALINITY, BICARBONATE	05-04-2015	67.0000000						MG/L
1929	ALKALINITY, CARBONATE	05-04-2015		<					MG/L
1930	TDS	05-04-2015	780.0000000				1000		MG/L
1994	AGGRESSIVE INDEX	05-04-2015	11.7300000						AGGR
1996	TEMPERATURE (CENTIGRADE)	05-04-2015	20.0000000						C
1997	LANGELIER INDEX (PH(S))	05-04-2015	0.4800000						LANG
2905	FOAMING AGENTS (SURFACTANTS)	05-04-2015		<			.5		MG/L
2931	1,2-DIBROMO-3-CHLOROPROPANE	05-04-2015		<			.2	.01	UG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
2946	ETHYLENE DIBROMIDE	05-04-2015		<			.05	.02	UG/L
C164	LANGELIER INDEX AT SOURCE TEMP.	05-04-2015	-0.1300000						LANG
C255	NITRATE (AS NO3)	05-04-2015	2.0000000		2		45	2	MG/L
4109	GROSS ALPHA PARTICLE ACTIVITY	04-21-2015	9.5000000		2	2.800	15	3	PCI/L
4109	GROSS ALPHA PARTICLE ACTIVITY	04-08-2015	9.8000000		1.9	2.800	15	3	PCI/L
1028	IRON	03-03-2015		<	100		300	100	UG/L
1028	IRON	12-01-2014		<	100		300	100	UG/L
1028	IRON	09-08-2014		<	100		300	100	UG/L
1080	CHROMIUM, HEX	07-01-2014	2.2000000		1		10	1	UG/L
1028	IRON	06-03-2014		<	100		300	100	UG/L
C255	NITRATE (AS NO3)	06-02-2014	3.0000000		2		45	2	MG/L
C255	NITRATE (AS NO3)	06-03-2013	2.3000000		2		45	2	MG/L
0100	TURBIDITY	05-07-2012	0.6800000		0.1		5	.1	NTU
1002	ALUMINUM	05-07-2012		<	50		1000	50	UG/L
1005	ARSENIC	05-07-2012	3.5000000		2		10	2	UG/L
1010	BARIUM	05-07-2012		<	100		1000	100	UG/L
1015	CADMIUM	05-07-2012		<	1		5	1	UG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
1017	CHLORIDE	05-07-2012	12.0000000				500		MG/L
1020	CHROMIUM	05-07-2012	1.7000000		10		50	10	UG/L
1021	HYDROXIDE AS CALCIUM CARBONATE	05-07-2012		<	3				MG/L
1022	COPPER, FREE	05-07-2012	260.0000000		50		1000	50	UG/L
1024	CYANIDE	05-07-2012		<	100		150	100	UG/L
1025	FLUORIDE	05-07-2012	1.1000000		0.1		2	.1	MG/L
1028	IRON	05-07-2012	660.0000000		100		300	100	UG/L
1030	LEAD	05-07-2012	17.0000000		5			5	UG/L
1031	MAGNESIUM	05-07-2012	12.0000000						MG/L
1032	MANGANESE	05-07-2012	22.0000000		20		50	20	UG/L
1035	MERCURY	05-07-2012		<	1		2	1	UG/L
1036	NICKEL	05-07-2012		<	10		100	10	UG/L
1039	PERCHLORATE	05-07-2012		<	4		6	4	UG/L
1041	NITRITE	05-07-2012		<	100		1000	400	UG/L
1042	POTASSIUM	05-07-2012	3.9000000						MG/L
1045	SELENIUM	05-07-2012		<	5		50	5	UG/L
1050	SILVER	05-07-2012		<	10		100	10	UG/L
1052	SODIUM	05-07-2012	49.0000000						MG/L
1055	SULFATE	05-07-2012	120.0000000		0.5		500	.5	MG/L
1064	CONDUCTIVITY @ 25 C UMHOS/CM	05-07-2012	490.0000000				1600		UMHOS/CM
1074	ANTIMONY, TOTAL	05-07-2012		<	6		6	6	UG/L
1075	BERYLLIUM, TOTAL	05-07-2012		<	1		4	1	UG/L
1085	THALLIUM, TOTAL	05-07-2012		<	1		2	1	UG/L
1095	ZINC	05-07-2012		<	50		5000	50	UG/L
1905	COLOR	05-07-2012	10.0000000				15		UNITS
1915	HARDNESS, TOTAL (AS CaCO3)	05-07-2012	130.0000000						MG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
1919	CALCIUM	05-07-2012	31.0000000						MG/L
1920	ODOR	05-07-2012		<	1		3	1	TON
1925	PH	05-07-2012	8.3000000						pH
1927	ALKALINITY, TOTAL	05-07-2012	100.0000000						MG/L
1928	ALKALINITY, BICARBONATE	05-07-2012	120.0000000						MG/L
1929	ALKALINITY, CARBONATE	05-07-2012		<	3				MG/L
1930	TDS	05-07-2012	310.0000000				1000		MG/L
2030	P-ISOPROPYLTOLUENE	05-07-2012		<	0.5				UG/L
2210	CHLOROMETHANE	05-07-2012		<	0.5			.5	UG/L
2212	DICHLORODIFLUOROMETHANE	05-07-2012		<	0.5			0.5	UG/L
2214	BROMOMETHANE	05-07-2012		<	0.5			.5	UG/L
2216	CHLOROETHANE	05-07-2012		<	0.5			.5	UG/L
2218	TRICHLOROFLUOROMETHANE	05-07-2012		<	5		150	5	UG/L
2222	BIS(2-CHLOROETHYL) ETHER	05-07-2012		<	5				UG/L
2224	TRANS-1,3-DICHLOROPROPENE	05-07-2012		<	0.5		.5	.5	UG/L
2228	CIS-1,3-DICHLOROPROPENE	05-07-2012		<	0.5		.5	.5	UG/L
2246	HEXACHLOROBUTADIENE	05-07-2012		<	0.5			.5	UG/L
2247	METHYL ETHYL KETONE	05-07-2012		<	5			5	UG/L
2248	NAPHTHALENE	05-07-2012		<	0.5				UG/L
2251	METHYL TERT-BUTYL ETHER	05-07-2012		<	3		13	3	UG/L
2277	4-METHYL-2-PENTANONE	05-07-2012		<	5			5	UG/L
2378	1,2,4-TRICHLOROBENZENE	05-07-2012		<	0.5		5	.5	UG/L
2380	CIS-1,2-DICHLOROETHYLENE	05-07-2012		<	0.5		6	.5	UG/L
2408	DIBROMOMETHANE	05-07-2012		<	0.5			.5	UG/L
2410	1,1-DICHLOROPROPENE	05-07-2012		<	0.5			.5	UG/L
2412	1,3-DICHLOROPROPANE	05-07-2012		<	0.5			.5	UG/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
2413	1,3-DICHLOROPROPENE	05-07-2012		<	0.5		.5	.5	UG/L
2416	2,2-DICHLOROPROPANE	05-07-2012		<	0.5			.5	UG/L
2418	1,2,4-TRIMETHYLBENZENE	05-07-2012		<	0.5			0.5	UG/L
2420	1,2,3-TRICHLOROBENZENE	05-07-2012		<	0.5			.5	UG/L
2422	N-BUTYLBENZENE	05-07-2012		<	0.5			0.5	UG/L
2424	1,3,5-TRIMETHYLBENZENE	05-07-2012		<	0.5			0.5	UG/L
2426	TERT-BUTYLBENZENE	05-07-2012		<	0.5			0.5	UG/L
2428	SEC-BUTYLBENZENE	05-07-2012		<	0.5			0.5	UG/L
2430	BROMOCHLOROMETHANE	05-07-2012		<	0.5			.5	UG/L
2904	TRICHLOROTRIFLUOROETHANE	05-07-2012		<	10		1200	10	UG/L
2905	FOAMING AGENTS (SURFACTANTS)	05-07-2012		<	0.1		.5		MG/L
2931	1,2-DIBROMO-3-CHLOROPROPANE	05-07-2012		<			.2	.01	UG/L
2941	CHLOROFORM	05-07-2012		<	0.5		80	1	UG/L
2942	BROMOFORM	05-07-2012		<	0.5		80	1	UG/L
2943	BROMODICHLOROMETHANE	05-07-2012		<	0.5		80	1	UG/L
2944	DIBROMOCHLOROMETHANE	05-07-2012		<	0.5		80	1	UG/L
2946	ETHYLENE DIBROMIDE	05-07-2012		<			.05	.02	UG/L
2955	XYLENES, TOTAL	05-07-2012		<	0.5		1750	0.5	UG/L
2963	XYLENE, META AND PARA	05-07-2012		<	0.5		1750	.5	UG/L
2964	DICHLOROMETHANE	05-07-2012		<	0.5		5	.5	UG/L
2965	O-CHLOROTOLUENE	05-07-2012		<	0.5			0.5	UG/L
2966	P-CHLOROTOLUENE	05-07-2012		<	0.5			0.5	UG/L
2967	M-DICHLOROBENZENE	05-07-2012		<	0.5			.5	UG/L
2968	O-DICHLOROBENZENE	05-07-2012		<	0.5		600	.5	UG/L
2969	P-DICHLOROBENZENE	05-07-2012		<	0.5		5	.5	UG/L
2976	VINYL CHLORIDE	05-07-2012		<	0.5		.5	.5	UG/L



Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
2977	1,1-DICHLOROETHYLENE	05-07-2012		<	0.5		6	.5	UG/L
2978	1,1-DICHLOROETHANE	05-07-2012		<	0.5		5	.5	UG/L
2979	TRANS-1,2-DICHLOROETHYLENE	05-07-2012		<	0.5		10	.5	UG/L
2980	1,2-DICHLOROETHANE	05-07-2012		<	0.5		.5	.5	UG/L
2981	1,1,1-TRICHLOROETHANE	05-07-2012		<	0.5		200	.5	UG/L
2982	CARBON TETRACHLORIDE	05-07-2012		<	0.5		.5	.5	UG/L
2983	1,2-DICHLOROPROPANE	05-07-2012		<	0.5		5	.5	UG/L
2984	TRICHLOROETHYLENE	05-07-2012		<	0.5		5	.5	UG/L
2985	1,1,2-TRICHLOROETHANE	05-07-2012		<	0.5		5	.5	UG/L
2986	1,1,1,2-TETRACHLOROETHANE	05-07-2012		<	0.5			.5	UG/L
2987	TETRACHLOROETHYLENE	05-07-2012		<	0.5		5	.5	UG/L
2988	1,1,2,2-TETRACHLOROETHANE	05-07-2012		<	0.5		1	.5	UG/L
2989	CHLOROBENZENE	05-07-2012		<	0.5		70	.5	UG/L
2990	BENZENE	05-07-2012		<	0.5		1	.5	UG/L
2991	TOLUENE	05-07-2012		<	0.5		150	.5	UG/L
2992	ETHYLBENZENE	05-07-2012		<	0.5		300	.5	UG/L
2993	BROMOBENZENE	05-07-2012		<	0.5			.5	UG/L
2994	ISOPROPYLBENZENE	05-07-2012		<	0.5			.5	UG/L
2994	ISOPROPYLBENZENE	05-07-2012		<	0.5			0.5	UG/L
2996	STYRENE	05-07-2012		<	0.5		100	.5	UG/L
2997	O-XYLENE	05-07-2012		<	0.5		1750	.5	UG/L
2998	N-PROPYLBENZENE	05-07-2012		<	0.5			0.5	UG/L
C255	NITRATE (AS NO3)	05-07-2012		<	1		45	2	MG/L
4109	GROSS ALPHA PARTICLE ACTIVITY	04-02-2012	1.0200000		3	0.740	15	3	PCI/L
4030	RADIUM-228	12-19-2011		<	0.3	0.568		1	PCI/L

Analyte Number	Analyte Name	Sampling Date	Detected Level	Less Than	RL	Counting Error (+/-)	MCL	DLR	Unit
4109	GROSS ALPHA PARTICLE ACTIVITY	12-19-2011	0.3100000		3	0.570	15	3	PCI/L
C255	NITRATE (AS NO3)	07-05-2011	15.0000000		2		45	2	MG/L
2063	2,3,7,8-TCDD	07-25-2006		<			0.03	0.005	NG/L
8404	TERTIARY BUTYL ALCOHOL (TBA)	07-25-2006		<	2			2	UG/L
C033	ETHYL-TERT-BUTYL ETHER	07-25-2006		<	3			3	UG/L
C034	TERT-AMYL-METHYL ETHER	07-25-2006		<	3			3	UG/L
8404	TERTIARY BUTYL ALCOHOL (TBA)	01-15-2002		<	2			2	UG/L
C033	ETHYL-TERT-BUTYL ETHER	01-15-2002		<	3			3	UG/L
C034	TERT-AMYL-METHYL ETHER	01-15-2002		<	3			3	UG/L